


REMOTE IGNITION TRANSFORMERS Type TR2...



DESCRIPTION

The capacitive-discharge remote ignition transformers type TR2.. are generally used for the ignition of atmospheric gas burners installed in wall-hung boilers, water heaters, hot air generators, convectors, floor-standing boilers, etc.

They have been designed to reduce to a minimum the electromagnetic interference generated by the ignition discharge. In fact, the structure of these transformers enables them to be mounted close to the ignition electrode, thus reducing to a minimum the length of the high voltage cable producing most of the irradiated interference. Thanks to their various fixing and connection possibilities and numerous customizations, these transformers can be easily fitted to any type of application.

For its operation, the TR2.. transformer needs a special electronic circuit which is incorporated in flame control and safety units (among which the FC.. modules, the CM..FR control units and the DMR.. DTMR... control units), which are also equipped with a filter against conducted interference.

If necessary, the transformers can also be fitted with resistors for a further reduction of irradiated interference.

The transformers are covered by the Italian patent no. 01289096 granted on 25.09.1998 for:

An ignition device for a flame burner or the like permitting a limitation of radio interferences.

TECHNICAL DATA

Operating temperature range
- 20°C + 60°C

Protection degreeIP00

Recommended distance between the electrodes: 2÷4 mm

Max. ignition cable length: 1 mWeight 55 gr approx.


- Output voltage: 15 kV standard

18 kV on request

Input power (with standard driving circuit): 2.5VA

OVERALL DIMENSIONS

The transformers can be fixed using screws type M4x10.




CONSTRUCTION

The primary and secondary windings with ferrite nucleus are immersed in a kind of resin ensuring a high electrical insulation.

The transformers of this series are available in different versions according to the following options:





| Power supply cable | Description |
|--------------------|--------------------------|
| S2 | Stelvio 2-pole connector |
| S3 | Stelvio 3-pole connector |
| M2 | Molex 2-pole connector |
| M3 | Molex 3-pole connector |
| M4 | Molex 4-pole connector |
| F28 | Female fast-on 2.8 mm |
| F48 | Female fast-on 4.8 mm |
| F63 | Female fast-on 6.3 mm |
| TC | Point terminals |
| SN | Tin-plated |

Table 1

| High voltage cable | Description |
|--------------------|---------------------------------------|
| T4 | Female cylindrical terminal Ø 4 mm |
| F28 | Female fast-on 2.8 mm |
| FP28 | Flat male fast-on 2.8 mm |
| TF63 | Female cylindrical terminal Ø 6.35 mm |

Table 2

| Protection | Description |
|------------|---------------------|
| | No protection |
| PS | Silicone protection |
| PD | Straight protection |
| PC | 90° protection |

Table 3

| Resistors | Description |
|-----------|-----------------|
| 1k | 1 kΩ resistor |
| 2k7 | 2.7 kΩ resistor |

Table 4

| Options | Description |
|---------|--|
| | 15 kV output voltage (Spark ignition energy 5.9 mJ) |
| М | For single-electrode control units |
| Н | 18 kV output voltage |
| N | Grey enclosure |
| J | 90° PVC power supply cable |

Table 5

Part reference example:

"TR2/A_C100S3_CAT30T4PS R2K7 H": refers to a TR2 with clamping brackets, power supply cable length 100 cm (connector included), Stelvio 3-pole connector, high voltage cable length 30 cm with female cylindrical terminal diam. 4mm, silicone protection, 2.7 k Ω resistor and 18 kV output voltage.

CONNECTION

The various available connection possibilities and options include option M; this option indicates that the transformer is used in single-electrode applications. In this case, the secondary high voltage winding wire, which is usually connected to Earth, and therefore yellow/green-coloured, is connected to the safety device detection input to carry out ignition/detection functions; in these applications the wire is white-coloured.

INSTALLATION

- Connect and disconnect the ignition transformer only after switching off power supply.
- Respect the applicable national and European standards (e.g. EN 60355-1 / EN 50165) regarding electrical safety.
- Make sure the earth of the transformer and the earth of the electrical system are well connected (in no-singleelectrode versions).
- The device can be mounted in any position.
- Avoid placing high voltage cables close to other cables.
- Make sure the protection degree is suitable to the system.
- Reduce the ignition cable length to a minimum (this reduces stray capacitance and the possibility that the ignition cable acts like an antenna transferring interference to the nearby cables);
- Make ignition cables follow a separate path close to ground planes (this reduces the influence of interference on the remaining electrical wires);
- Arrange a single earth centre, thus preventing earth conductors from creating ring paths.

ATTENTION -> Company Brahma S.p.A. declines any responsibility for any damage resulting from the Customer's interfering with the device.

BRAHMA S.p.A.

Via del Pontière, 31 37045 Legnago (VR) - ITALY

Tel. +39 0442 635211 - Telefax +39 0442 25683 http://www.brahma.it - E-mail: brahma@brahma.it

2019/01/16 Subject to amendments without notice

2/2 4473_r04